



- ① 12" CAST IRON VALVE BOX COVER, ALHAMBRA FOUNDRY NO. A-29612 (12")
- ② SOUTH BAY FOUNDRY VALVE BOX SBF 1246W
- ③ 2" COPPER ADAPTER - COMPRESSION X FEMALE IRON PIPE ADAPTER JONES J-2607 (OAE).
- ④ 2" COPPER SERVICE TUBING, TYPE "K" - SOFT
- ⑤ 4" FLGxMJ RESILIENT WEDGE GATE VALVE. SLIP CAN AND LID PER ALW DWG. NO. W-10.
- ⑥ 2" CORPORATION STOP, IPT JONES J-1943 OR FORD FB 500-7 (OAE).
- ⑦ DUCTILE IRON MECHANICAL JOINT TEE WITH 4" FLANGED OUTLET.
- ⑧ 2" ADAPTER - PACK JOINT CONNECTION SERVICE FITTING - MALE IRON PIPE THREAD X PACK JOINT COMPRESSION ADAPTER JONES J-2606 (OAE)
- ⑨ INSTALL A CONCRETE THRUST BLOCK PER ALW DWG. NO. W-7.
- ⑩ 4" FLANGED X MECHANICAL JOINT LONG RADIUS 90° DUCTILE IRON ELBOW.
- ⑪ 4" DUCTILE IRON CLASS 350 PIPE WITH POLY-WRAP.

NOTE: (OAE) - OR APPROVED EQUAL. 2-INCH BLOW-OFF ASSEMBLY FOR 12-INCH DIAMETER PIPE AND SMALLER. MAXIMUM WORKING PRESSURE 150 PSI. RESTRAIN ALL JOINTS. POLY-WRAP ALL DUCTILE IRON PIPE AND FITTINGS.

## WATER STANDARD



**DRAWN:** M. BARBOSA

**DATE:** 10-11-2012

**SCALE:** AS SHOWN

### 2" BLOW-OFF ASSEMBLY

APPROVED: *Chof Anderson* 40330 10/15/12  
 ASSISTANT DIRECTOR - WATER OPERATIONS RCE NO. DATE

**DWG. NO.**

**W - 13**

**SHEET**  
**1 of 1**